

Theatre Act 1968  
Renewal of Licence  
At:

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

St Machar Academy St Machar Drive

- 1) I am awaiting confirmation regarding the Certification for the overhead lights and gantries.
- 2) Electrical cables on the stairways leading to the stage from the main hall from both sides require to be secured to remove a potential tripping hazard.
- 3) Emergency door at the side of the hall requires easing as it was rubbing against the adjacent door.
- 4) Double Socket in the hall requires to be suitably secured.

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

[REDACTED]

Regards

Raymond Morrison

Raymond Morrison  
Senior Authorised  
Licensing Standards Officer  
Environmental Health and Trading Standards  
Housing and Environment  
Aberdeen City Council  
Business Hub 15  
Third Floor South  
Marischal College  
Broad Street

**From:** "macleodm" <macleodm@st-macharacademy.aberdeen.sch.uk>  
**To:** <BILLG@aberdeencity.gov.uk>  
**Date:** 16/02/2012 10:34  
**Subject:** Theatre Licience

Hi Bill

Items 2,3, and 4 have been attended to by the school. John Muirhead was asked to confirm certification for the overhead lights and gantries. I believe he has had the work carried out but I'm unsure what he has done with the certificate. I will follow this up and get back to you.

Thanks

Morris MacLeod  
School Support Services Manager