

From: Kenny Simpson
To: Bill Gordon
CC: LicensingCommittee
Date: 05/03/2013 15:54
Subject: Aberdeen Sports Village

Hi Bill

Having inspected the sports village comments were passed to the management with regard to the ongoing maintenance of their fire doors and the management of the external escape routes during the construction of the adjacent swimming pool. Additional escape signage has been recommended within the large sports hall.

On the basis that these recommendations are implemented, Building Standards have no objections to the issuing of the licence

Regards
Kenny

Kenny Simpson
Team Leader
Building Standards
Strategic Leadership
Aberdeen City Council
Marischal College
Business Hub 4
Broad Street
Aberdeen
AB10 1AB
Tel. 523362 Fax. 523180

We are committed to improving the quality of the service we provide and would like to know your views on the service you have received.

By clicking on <http://www.aberdeencity.gov.uk/customerfeedback> selecting Building Standards and filling out the online feedback form, you will be helping us learn what we need to do better