




## Technical Advice Note (TAN)

Title: The Repair and Replacement of  
Windows and Doors


Date: February 2016

# Technical Advice Note

## The Repair and Replacement of Windows and Doors



Planning and Sustainable Development  
Enterprise, Planning and Infrastructure  
Aberdeen City Council  
Business Hub 4, Ground Floor North  
Marischal College  
Broad Street  
Aberdeen  
AB10 1AB  
Telephone: 01224 523470  
Fax: 01224 523180  
Email: [pi@aberdeencity.gov.uk](mailto:pi@aberdeencity.gov.uk)



**aberdeen** local development plan

# Contents

1.	Introduction	1
2.	Thinking About Change	2
3.	Why Do We Need to Manage Change?	3
4.	Do I Need Consent?	4
5.	Listed Buildings, Conservation Areas and Other Areas of Special Control	5
6.	Retain, Restore, Repair, Refurbish and Replace	7
7.	Inserting New and Blocking Up Old	15
8.	Building Regulations	16
9.	Bats	16
10.	Summary Charts – What Could Be Acceptable Where?	17
11.	What To do Next	19
12.	Glossary	21
13.	Further Reading	23
	Appendix 1 Professional Survey	24
	Appendix 2 Building Standards Information	25



## 1. Introduction


This is one in a series of **Technical Advice Notes** (TANs) produced by Aberdeen City Council to help explain the Council's policies on various aspect of development in the City and who to contact for further information and advice.

This TAN addresses the **Repair and Replacement of Windows and Doors** and applies to all properties in the City. It:

- provides advice and guidance to residents and developers who are considering the repair or replacement of windows or doors;
- provides advice on whether any approvals are required before undertaking works (e.g. Planning Permission, Listed Building Consent, Building Warrant), and how to apply for these approvals;
- is a 'material consideration' and will assist Officers within Aberdeen City Council in determining applications;
- explains why windows, doors and doorways are important features of traditional buildings;
- outlines the Council's expectations for properties which are Listed Buildings and / or within a Conservation Area;
- provides 'best practice' guidance on suitable replacement windows and doors where repair is not an option; and,
- advises on measures to enhance the efficiency and security of older windows and doors without having to replace them.

A Further Reading list is provided at the rear of the guide (Section 13), along with a Glossary (Section 12) to explain terms which may not be familiar. The TAN does not include guidance on new dormer windows or rooflights, as these are covered separately within the Householder Development Guide Supplementary Guidance, available at:

[www.aberdeencity.gov.uk/localdevelopmentplan](http://www.aberdeencity.gov.uk/localdevelopmentplan).



*Windows, doors and doorways can be important features of a building which are important to protect*

## 2. Thinking About Change

There are a number of reasons why owners might consider replacing their windows or doors, however the most common reasons are generally to do with concerns over heat loss, sound proofing, security and maintenance.

The general assumption is that these types of issues can only be resolved by completely replacing original windows and doors with something new – such as new ‘double glazing’. This is however often unnecessary, and can be extremely costly and unsustainable.

Below are a number of questions to consider before deciding whether replacing your windows or doors is right for you:

- Do my windows or doors actually need replacing or would it be more cost effective and sustainable to repair them?
- How old are my existing windows or doors? Are they of local or historic value or interest? Do they add value to my house?
- Are there upgrades which can be made to my existing windows to address heat loss, sound proofing and security?
- Can any parts of my existing windows or doors be recycled or reused if they cannot be repaired?
- Will new windows or doors really result in less maintenance?
- How long will it take for any savings in my heating costs to pay for the cost of new units, and how long will the new units last?



*Repair of sash & case windows can often be much cheaper than replacement*

### 3. Why Do We Need to Manage Change?

Windows, doors and doorways are distinctive features of a building which can often tell us a lot about local history and social change. In areas of Aberdeen where buildings have little decoration, traditional windows can make an important contribution to a building's architectural interest.

Changes to windows and doors which are well managed can make a positive contribution to the design and appearance of a building and to the quality and character of the surrounding area. Inappropriate changes can however have a significant negative impact on the character or appearance of a building which, when repeated over time, can dilute the appeal of wider areas.

For Listed Buildings and Conservation Areas inappropriate change can be particularly damaging, and may result in drops in property values. Unauthorised change may also lead to legal enforcement action.

Unauthorised windows and other works can also be identified by conveyancing solicitors and can affect property sales.



*Inappropriate change can negatively affect streets and wider areas as well as individual buildings*

To check if your property is a Listed Building, visit: [www.historic-scotland.gov.uk/historicandlistedbuildings](http://www.historic-scotland.gov.uk/historicandlistedbuildings).

To check if you live within a Conservation Area, visit: [www.aberdeencity.gov.uk/masterplanning](http://www.aberdeencity.gov.uk/masterplanning).




## 4. Do I Need Consent?

In some instances the amendment or replacement of windows and doors is controlled by planning legislation and permission is required before undertaking any works.

**This diagram should help you to work out whether or not permission would be required for your proposal.**

If your proposals are for an exact replica of an existing window or door then consent may not be required if the proposals match the existing in every way.

If you are unsure whether consent would be required you should always check with the Council's Development Management Section first, as unauthorised works could lead to costly enforcement action.



## 5. Listed Buildings, Conservation Areas and Other Areas of Special Control

### 5.1 Listed Buildings

In Aberdeen, Listed Buildings range from grand villas on Queens Road, to tenement blocks on Rosemount Viaduct and fishermen's cottages at Footdee. Each Listed Building has its own character and style, be it individually, or as part of a wider group of buildings.

All Listed Buildings are protected, not just those in Conservation Areas, and all elevations of a Listed Building are protected, regardless of the Category of Listing.

Listed Building Consent will almost always be required for the alteration or replacement of windows or doors in Listed Buildings. In some instances repairs to traditional windows and doors using the original materials ("like for like") may not require Listed Building Consent. For proposals not to require consent they must include exact replication of the opening method and materials. For windows they must also include exact details of astragal dimensions and profiles, fixing of glass and the reuse of historic glass where this contributes to a building's character.

In considering applications for Listed Building Consent, the Council is required by law to: "...have special regard to the desirability of preserving the building or its setting or any features of special architectural or historic interest which it possesses" (Planning (Listed Buildings and Conservation Areas) (Scotland) Act 1997). If the Listed Building is situated in a Conservation Area, or is part of a flatted property, Planning Permission may also be required.

It is recommended that you check with the Council's Development Management section prior to undertaking any works to receive confirmation as to whether any consents would be required.



*Building may exhibit a variety of window sizes and glazing patterns. This can provide important evidence of the history of the building and contribute to its character and interest*



## 5.2 Conservation Areas

Conservation Areas are areas of the City which have been designated by the Council for their special architectural or historic interest. Aberdeen has 11 Conservation Areas within the City Boundary, which include areas such as Old Aberdeen, Ferryhill and Rosemount / Westburn. Appraisals of Conservation Areas in Aberdeen are available at [www.aberdeencity.gov.uk/masterplanning](http://www.aberdeencity.gov.uk/masterplanning).

If your property is not a Listed Building but is located within a Conservation Area then you will require Planning Permission to alter or replace windows or doors other than on a “like for like” basis. If your property is both a Listed Building and located in a Conservation Area then you will need to apply for both Listed Building Consent and Planning Permission. These requirements apply to both modern and older, traditional, properties.

In considering applications for Planning Permission in Conservation Areas, the Council is required by law to pay special attention “*to the desirability of preserving or enhancing the character or appearance of that area*”. (Planning (Listed Buildings and Conservation Areas) (Scotland) Act 1997). For Listed Buildings within Conservation Areas, Planning Permission will be required in addition to Listed Building Consent.

## 5.3 Other Areas of Special Control

For properties which are not Listed Buildings or within Conservation Areas, permitted development rights can exist so that small alterations to properties, such as replacing windows or doors, can be undertaken without the need for some permissions. These are not however applicable in the following circumstances:

Burnbanks and Kingswells



*Details of the Conservation Areas in Aberdeen can be found on the Council's website, [www.aberdeencity.gov.uk](http://www.aberdeencity.gov.uk).*

In both Burnbanks Village and Kingswells the City Council has taken the decision to remove some or all Permitted Development Rights via an Article 4 Direction, and so planning permission for replacing or amending windows / doors in these areas will be required.

The general preference will be for original or historic windows and doors in areas covered by an Article 4 Direction to be repaired and restored wherever possible. Where there is no original or historic fabric to be retained then any assessment of replacement proposals will principally be based on styling/type, materials and colouring.

### Flats

If you live in a flatted property, planning permission will be required if you intend to alter the dimensions of an existing window or door opening.

## **6. Retain, Restore, Repair, Refurbish and Replacement**

### **6.1 Retain, Restore and Repair**

Windows and doors can almost always be improved by being repaired, even if they are in very poor condition. Repair is also preferred in terms of sustainability as it reduces the requirement for new raw materials and energy. Traditional windows and doors are extremely durable and when properly maintained can last for centuries - many in Aberdeen are already well over 100 years old.

The repair of original windows and doors is the best means of safeguarding the historic character of a traditional building, and in maintaining the visual character of wider areas. Repair will always be promoted over replacement, as new, modern, units will very rarely be capable of matching the character and visual interest of the units to be replaced.



*Examples of rectangular panes and curved glass*

Traditional windows are nearly always timber sash and case and are found in a variety of forms that reflect changing glass technology and architectural fashion. Timber sash and case windows are a recognised feature of Aberdeen's traditional buildings, and are generally of a straightforward design and construction, meaning that they can usually be easily repaired.

Curved corner windows and rectangular "lying" panes of glass are features which are particularly special to Aberdeen must always be retained.

Traditional external doors and doorways are usually of solid timber frame construction with inset panelling retained by mouldings. Throughout the 18<sup>th</sup> and 19<sup>th</sup> centuries panelled doors became standard for the main entrance of most types of building. In Aberdeen this was typically reflected in 4, 5 and 6 panel varieties in a number of different configurations. A good joiner should be able to treat most faults with traditional doors, and again repair should be less expensive than replacement.

Original door ironmongery such as letterboxes, door knockers and handles should be retained and reused wherever possible, as should original window fittings such as cord clamps, sash lifts, sash fasteners and hooks.



*4 panelled door with associated door ironmongery / furniture*

## 6.2 Refurbish

Traditional windows and doors can be upgraded at a lower cost to bring these same benefits, whilst still retaining the original features and style which gives character to your building.

### Energy Efficiency

Traditional windows and doors can be upgraded to increase energy efficiency, and improve sound insulation and security, often at a lower cost than replacing units, whilst still retaining the original features and style which gives character to buildings. Historic Environment Scotland's



*Draught-proofing strips can be easily applied to interior side of external door*



research and guidance on improving energy efficiency in traditional buildings can be found in their [Technical Conservation Knowledge Base](#).

Draught-proofing simply means blocking up any unwanted gaps which let cold air in and warm air out. Keeping warm air in the building means less energy spent heating it, therefore saving you money. A number of draught-proofing measures are widely available from DIY stores and can be fitted relatively cheaply.

Traditional timber doors are generally very effective in retaining warm air within a building, however additional insulation material can be added to the panels on the indoor side of the door to enhance the effect and fight additional heat loss whilst still maintaining the character of the door from the outside.

Where installing draught-proofing to traditional windows is difficult, **secondary glazing** systems can be a good alternative. Secondary glazing consists of an additional pane of glass fitted on the inside of the existing window frame which can be removed during summer months and for cleaning. Providing similar insulation values to double glazing, it can also reduce dust ingress, provide good noise insulation, and be an extra security measure.

Secondary glazing design should seek to be as discreet as possible, particularly in Listed Buildings, with small frames concealed from view. Meeting rails and frames should be as small in section as possible to allow them to be disguised behind existing rails. If secondary glazing is installed, the original windows should not be draught-proofed to help avoid condensation.

For more information about improving energy efficiency in traditional properties a number of Historic Environment Scotland's publications are included in the Further Reading List at the end of this document (Section 13).



*Secondary glazing should seek to be as discreet as possible*

### 6.3 Reinstate Windows and Doors

To reiterate, original or historic windows, doors and doorways must be repaired and restored rather than replaced. Modern windows and doors which are unsympathetic should be restored to original types and arrangements, which are more appropriate to the age and character of the building. The reinstatement of the original types and arrangements of windows will be encouraged - except where there is a demonstrable benefit in retaining later fenestration as examples of window and glazing technology. If there is no indication what the original windows were like, then authentic historic precedents can often be found on neighbouring properties.

#### 6.4 Replace Windows and Doors


Complete replacement of traditional windows and doors should only be contemplated where the features have deteriorated to an extent where repair is not possible, and with Listed buildings evidence of this will be required as part of the Listed Building Consent application. This evidence should take the form of a Professional Survey, further details on which are provided in Appendix 1.

##### Windows

To ensure architectural integrity replacement windows should replicate the historic design exactly in terms of materials, proportions, profiles and dimensions of frames and glazing bars/ astragals and method of opening and details. Drawings will specify cross sections, plans, relationship at jambs/ sills and details such as mouldings, at a scale of 1:5 at A3. Replacement windows should re-use historic glass including stained, leaded or etched glass, where this contributes to a building's character. Proposals to use wired glass, obscured glass, louvered glass or extract fans in windows will not generally be considered acceptable.

##### Listed Buildings and public elevations of unlisted buildings in conservation areas

On Listed Buildings and public elevations of unlisted buildings in Conservation Areas, the introduction of PVCu windows as a replacement material is not acceptable.



*Sash & case window illustration*



Many historic windows in Aberdeen are timber sash and case. The relative proportions of the upper and lower sashes of new windows must be the same as in the original windows, as should the size of timber sections. Replacement windows should be fitted in the same plane, be made up from timber sections of the same profile and dimensions, and have the meeting rails in the same position.

Generally, when the window is fully closed, the visible part of the sash stiles, top rail and meeting rails should be of a similar width/depth. Where there is no existing original model on which to base a replica, bottom rails should be at least 75mm deep and 25mm deeper than the meeting rails, on elevation. No more than 20-25mm of the sash box should be visible in the window opening, the remainder being concealed behind the masonry window check.

#### Non-public elevations of unlisted buildings within Conservation Areas

On non-public elevations of unlisted buildings within Conservation Areas, the context and setting of the building is required to be assessed to ensure proposals will have no detrimental impact on the character and appearance of the Conservation Area. Replacement windows should match the historic proportions, profile and dimension of the original windows and avoid heavy frames, but it may be acceptable to have a different material and/or method of opening.

If existing non original/historic windows on the public elevation of an unlisted building within conservation area are being replaced, the reinstatement of the original types and arrangements of windows will always be encouraged. The reinstatement of approved one over one PVCu sash and case windows will only be allowed if:

- no more than 25mm of the outer window frame should be visible at the top and sides, once the window has been fitted into the masonry opening;
- the meeting rails must fully overlap.
- the bottom rail of the lower sash must be at least 75mm high.
- the glass must be recessed from the front face of the sash by at least 10mm.
- on bay windows no more than 25mm of the frame should be visible in the window opening, the remainder being concealed behind the masonry window check. A frame which encroaches more than 25mm will not be acceptable

On non-traditional, more modern, unlisted buildings in Conservation Areas a broader range of materials and designs may be permitted, depending on the individual building and surrounding area.

### Ventilators

Ventilators cut through the glass or visible on the window frames will not be considered acceptable on Listed Building or public elevations of unlisted building in Conservation Areas. Ventilators, where required, should be located unobtrusively in the meeting rail. Where trickle ventilation is required other more discreet means of achieving this should always be considered. Historic Scotland's publication "[Sash & Case Windows: A Guide for Homeowners](#)" provides further guidance on ventilation.

### Astragals

Consent for replacement windows where the astragals are merely applied to the surface of, or are sandwiched between, the panes of glazing will be refused. Where astragals are required, they must be kept slender to match the thickness of the original astragals, particularly in multiple pane sashes.

### Putty and Beads

Glazing in windows on Listed Buildings should preferably be retained in position with traditional putty or modern butyl based putty, which is always preferred to timber beads. Where glazing beads are required they should be wedge shaped to match a putty fillet, and taper from 10mm at the glass to less than 2mm at the outside. The edge of the bead must be flush with, or kept slightly back from, the face of the sash. It must never project out from the face of the sash, or an unacceptable shadow line will be created around each pane of glass. The dimensions of replacement window astragals should use original sash windows as the model. Typically astragals may only be 17-19mm wide. In Listed Buildings, the internal profile of the astragals must not be over-simplified, but should reproduce traditional moulding appropriate to the period and detail of the building. Astragals must carry through the sash to completely separate each pane of glass.



*Discreet means of achieving ventilation will be required*

## Horns


Elsewhere in the country most mid/late Victorian windows have 'horns' however this is not the case in Aberdeen. Along with original Georgian and early Victorian windows, most nineteenth century windows in Aberdeen do not have horns, and neither should the windows which replace them. The use of horns should only be contemplated only where there is clear evidence that they existed on the original windows, and in such instances the design of the horns should match the original.

## Doors

Where there is no alternative to the replacement of an original door on a Listed Building or on a public elevation of an unlisted building within a conservation area, new elements must match the original in all respects. The new door should match the original in terms of proportion, profile, opening method and material, and reuse historic glass where this contributes to a building's character. If the property forms part of a group of uniform design, then any replacement should make reference to those of the neighbouring properties in style, design and size. Joiner-made timber replicas are a requirement on Listed Buildings and will be strongly encouraged in Conservation Areas.

Composite door solutions on unlisted buildings may be appropriate on public elevations in Conservation Areas depending on the specified design proposed. If the existing door is surrounded with side lights and fan lights, and/ or mouldings these elements are required to be retained. If installing a composite door and doorframe would result in the loss of these features the proposal will be refused

On non-public elevations of unlisted buildings within Conservation Areas, the context and setting of the building is required to be assessed to ensure proposals will have no detrimental impact on the character and appearance of the Conservation Area. Replacement doors should match the historic proportions, profile and dimension of the original but it may be acceptable to have a different material and/or method of opening.



*Historic glass should be reused where this contributes to the character of a building*

Replacement doors with a stained or varnished finish, and those which introduce asymmetrical elements, integral fanlights, inappropriate glazing or panelled patterns, will also be rejected.

The original proportions of doorways and door openings on street frontages must always be retained, and proposals to recess a door either less or more deeply within the door opening will not be supported. Original door ironmongery such as letterboxes, door knockers and handles should be retained and reused if the timber door is being replaced. Where this does not survive, the replacement of modern fittings with items appropriate to the period of the building will be encouraged.

Where the opportunity exists, modern doors which are badly proportioned, or of the wrong type or material, should be replaced with a more appropriate solution.

### Colour Palette

White has been the default colour of window repairs and replacements for the past 20 years. In order to encourage uniformity new windows will be white. This will be particularly important in tenements where the use of a uniform window colour helps give the building an architectural cohesion it may otherwise lack. Other colours will need to be agreed.

Doors should be painted in an appropriate dark and muted colour, and bright glosses and white paint avoided. Stained or varnished wood finishes will generally be unacceptable.



*Replacement windows will generally require to be white*

## 7 Inserting New and Blocking Up Old

Applications to insert additional windows in Listed Buildings or in Conservation Areas may be permitted where this does not detract from the character of the building or area.


Location and design are the key considerations for new window openings which should be assessed in the context of the rest of the building and surrounding properties. The blocking up, in whole or in part, of original openings should only occur where the window makes little contribution to the building or area.

In principle the blocking up should be done in materials that relate to the surrounding building and evidence of the opening, such as window surrounds, be retained.

Proposals to increase the glazing area by removing stone or timber mullions which form the divisions in bipartite or tripartite windows will not be supported on Listed Buildings or in Conservation Areas.

The re-opening of blocked windows will be encouraged only where this will reinstate the intended elevational treatment of the building. It will not be permitted in cases where blocking up has taken place during later alterations to the structure and where the earlier window openings consequently no longer relate to present elevational form.

Doors in street frontages, even though no longer used, should always be retained



*Example of blocked up windows in Ferryhill*



## 8 Building Regulations

Building Regulations exist to protect the public and for replacement windows and doors cover aspects such as ventilation, safety from collision, safe cleaning, prevention of falls, thermal performance and means of escape.

There is no need to obtain Building Warrant approval for replacing your windows or doors, but the work you undertake should meet the requirements of the Building Regulations, and the responsibility for compliance rests with the owner.

This guidance applies whether or not the new window or door is to be the same style and material as the existing.

Repairs to an existing window are slightly different and can be completed to return the window to the original standard without the need for the repaired window meeting current standards e.g. replacing the cill.

It is recognised that compliance with all Building Regulations may be difficult in buildings that have existing historical features or are Listed. Further advice on relaxations can be sought from the Building Standards Team at 01224 523470 or [pi@aberdeencity.gov.uk](mailto:pi@aberdeencity.gov.uk). Further guidance on Building Regulations can be found in Appendix 2.

## 9 Bats

If you are considering repairing or replacing any windows or doors you should also consider the possibility of bats being present. Bats and bat roosts can be found in many kinds of building, old or new, and can sometimes be found roosting in windows frames, window sills, doorways, lintels and porches.

Bats are European Protected Species (EPS) and are protected by European, UK and Scottish Law. The main piece of the legislation in the UK for the protection of bats is the Conservation (Natural Habitats, &c.) Regulations 1994 (as amended). If you do not require planning permission for the amendment or replacement of your windows or doors, however suspect that you may have roosting bats, a bat survey will confirm this and whether a licence from Scottish Natural Heritage is likely to be required.

Further information about bats, surveys and surveyors can be found in our Bats and Development Supplementary Guidance.

## 10. Summary Charts - What Could Be Acceptable Where?

The following tables have been produced for general guidance purposes only. Proposals will still require to demonstrate satisfactory detailed designs and implementation methods. The charts should only be read in the context of the advice provided within the rest of this TAN. Alterations and works to **non-pubic elevations of unlisted buildings in conservation areas** may still require consent. Alterations to Listed Buildings may require Listed Building Consent and planning permission may be required to alter any elevation of properties in conservation areas.

Any queries should be directed to the Council's Development Management Section

### Windows

	Listed Buildings	Conservation Areas: Public Elevations
Retain, repair and refurbish original/historic window frames and glazing	Consent not required	Consent not required
Secondary glazing	Consent not required in most instances. Please check.	Consent not required in most instances
Window survey required to remove original/historic window (frames and /or fabric)	✓	N/A
Reinstate original types and arrangements – with exceptions	✓	✓
Timber replica/reinstatement	✓	✓
Reuse historic glass/ironmongery and window fittings in replacement windows	✓	✓
Retaining and reuse historic or original stained / decorative leaded glass and etched glass	✓	✓
Replace original/historic frames with different material	X	X

Through astragals	✓	✓
Visible Ventilators	X	X
Horns	X	X

### Doors and Doorways

	Listed Buildings	Conservation Areas: Public elevations
Retain, repair and refurbish original/historic	Consent not required	Consent not required
Reinstate original types and arrangements	✓	✓
Joiner made timber panelled door	✓	✓
Composite Door	X	✓ in certain circumstances
uPVC / aluminium / DIY chain store door	X	X
Flush (e.g. plywood) doors with mouldings applied	X	X
Reuse historic Ironmongery	✓	✓

## 11. What To Do Next

Applications for Planning Permission and / or Listed Building Consent can be made online via the Scottish Government's e-planning website: <https://www.eplanning.scot/ePlanningClient/>

Or direct to Aberdeen City Council using the application forms available at: [www.aberdeencity.gov.uk/planning\\_environment](http://www.aberdeencity.gov.uk/planning_environment)

For applications for Planning Permission an application fee will be required. There is no charge for applications for Listed Building Consent, however a fee may be requested to advertise the application in the local press.

Failure to obtain appropriate consents and permissions could result in enforcement action being taken to have unauthorised windows or doors replaced, which may entail considerable costs for the building owner. Unauthorised windows and other works are often identified by conveyancing solicitors and can affect property sales.

In the case of a Listed Building unauthorised work falls under criminal law, and so the person who executes the works, or causes them to be executed, is liable to prosecution or imprisonment in addition to standard enforcement proceedings.

### Submission Requirements

Two (2.no) copies of the following scaled drawings will be required for applications for Planning Permission and three (3.no) for Listed Building Consent in addition to the relevant application forms:



#### **For further information please contact:**

Planning and Sustainable Development  
Aberdeen City Council  
Business Hub 4, Ground Floor North  
Marischal College  
Broad Street  
Aberdeen  
AB10 1AB

Telephone: 01224 523470

Fax: 01224 523180

Email: [pi@aberdeencity.gov.uk](mailto:pi@aberdeencity.gov.uk)

1. An OS Plan which clearly identifies the location of the site
2. Plans and detailed elevations of both existing and proposed works.
3. Horizontal and sectional drawings with details at a larger appropriate scale.
4. Details of proposed materials and style of opening.
5. Any other relevant technical information and photographs

In addition, for applications for the replacement of windows/doors on a Listed Building or within a Conservation Area, the following will also be required:

6. A clear statement which sets out a justification for the proposals, including why the works are desirable or necessary.
7. Detailed justification (e.g. a professional survey – for more information refer Appendix 1) to demonstrate to the satisfaction of the Council that the windows/doors to be replaced are beyond economic repair. Within Conservation Areas this will only be required for proposals affecting front elevations or elevations which are visible from public areas.
8. Drawings will normally be required at a scale of 1:1 or 1:2 and should include sections through window head, meeting rails, bottom rail and cill, window jambs and astragals. In addition, an elevation of the window should be provided showing the position of the meeting rails and the arrangement of any astragals.

### **Sources of Assistance**

If your property is a Listed Building or situated within a Conservation Area then you may wish to investigate whether any sources of funding assistance exist:

- The Aberdeen City Heritage Trust is a limited company and charity that operates within Aberdeen City. The Trust has its own criteria for determining in what circumstances it may be prepared to offer assistance. Further details can be found on its website [www.aberdeenheritage.org.uk](http://www.aberdeenheritage.org.uk) or by calling 01224 522755
- Historic Scotland also administers a programme of building repair grants throughout Scotland for Listed Buildings of outstanding architectural or historic importance, or key buildings within Conservation Areas. More information is available at [www.historic-scotland.gov.uk/grants](http://www.historic-scotland.gov.uk/grants)



## 12. Glossary

**Article 4 Direction:** Some types of development do not need planning permission by virtue of permitted development rights. An Article 4 Direction is an order made by Scottish Ministers which suspends (for specified types of development) the general permission granted under the Town and Country (General Permitted Development) (Scotland) Order 1992 (as amended), thereby removing permitted development rights. Article 4 Directions are currently in place in Burnbanks and parts of Kingswells.

**Astragal:** A glazing bar separating panes of glass within a window.

**Conservation Area:** Conservation Areas are areas of special architectural or historical interest, the character or appearance of which it is desirable to preserve or enhance. Such areas are designated by the local planning authority. Details of the Conservation Areas in Aberdeen can be found via [www.aberdeencity.gov.uk/masterplanning](http://www.aberdeencity.gov.uk/masterplanning).

**Dwellinghouse:** For the purposes of this guidance, the term “dwellinghouse” does not include a building containing one or more flats, or a flat contained within such a building

**Fenestration:** The arrangement / pattern of the windows in a building.

**Flat:** A separate and self contained residence, which is one of several within a larger building.

**Lintel:** A structural beam above an opening, such as a window or door,

**Listed Building:** Working on behalf of Scottish Ministers, Historic Scotland inspectors identify buildings which are worthy of statutory protection. These are ‘Listed Buildings’. The criteria by which the Scottish Ministers define the necessary quality and character under the relevant legislation are broadly; Age and Rarity; Architectural Interest; and Close Historical Association A list of listed building is available from Historic Scotland [www.historic-scotland.gov.uk/historicandlistedbuildings](http://www.historic-scotland.gov.uk/historicandlistedbuildings).

**Listed Building Consent:** Although the listing of a building should not be seen as a bar to all future change, strict controls do exist to ensure that works undertaken to Listed Buildings are appropriate. Listed Building Consent is obtained through an application process which is separate from, but runs parallel to, applications for planning permission. This separate regulatory mechanism allows planning authorities to ensure that changes to listed buildings are appropriate and sympathetic to the character of the building.

**Material Consideration:** Any issue which relates to the use and development of land and is relevant to the planning process.

**Mullion:** A vertical piece of stone or timber dividing a window into sections.

**Permitted Development:** A term used for certain types of development which, by satisfying specified conditions, is automatically granted planning permission without the submission of an application to the planning authority. These Permitted Development Rights are removed for Listed Buildings, Conservation Areas, Article 4 areas, and flats.

**Planning Authority:** The term given to the Council in its role exercising statutory functions under Planning legislation. Authorities have three main planning duties: Development Management (assessing and determining planning applications); Development Planning (preparing, updating and monitoring the authority's Local Plan/Local Development Plan); and Enforcement (seeking to investigate and resolve breaches of planning control)

**Sash and Case Window:** A window that slides vertically on a system of cords and balanced weights.

**Terrace House:** A dwellinghouse situated in a row of three or more buildings

**Transom:** A horizontal glazing bar in a window.

## 13. Further Reading

- **Aberdeen Local Development Plan**  
[www.aberdeencity.gov.uk/localdevelopmentplan](http://www.aberdeencity.gov.uk/localdevelopmentplan)
- **Bats and Development Supplementary Guidance**  
<http://www.aberdeencity.gov.uk/nmsruntime/saveasdialog.asp?IID=47678&sID=14394>
- **Householder Development Supplementary Guidance**  
<http://www.aberdeencity.gov.uk/nmsruntime/saveasdialog.asp?IID=45460&sID=14394>
- **Conservation Area Appraisals**  
[www.aberdeencity.gov.uk/masterplanning](http://www.aberdeencity.gov.uk/masterplanning)
- **Historic Scotland - Energy Efficiency Advice**  
<http://www.historic-scotland.gov.uk/index/heritage/technicalconservation/energyefficiencyadvice.htm>
- **Historic Scotland - Managing Change in the Historic Environment: Doorways**  
<http://www.historic-scotland.gov.uk/index/heritage/policy/managingchange.htm>
- **Historic Scotland - Managing Change in the Historic Environment: Windows**  
<http://www.historic-scotland.gov.uk/index/heritage/policy/managingchange.htm>
- **Historic Scotland – Sash & Case Windows: A Short Guide for Homeowners**  
<http://www.historic-scotland.gov.uk/maintaining-your-home.pdf>
- **Scottish Historic Environment Policy**  
[www.historic-scotland.gov.uk/index/heritage/policy/shep.htm](http://www.historic-scotland.gov.uk/index/heritage/policy/shep.htm)

## **Appendix 1: Professional Survey**

National planning policy only allows windows in Listed Buildings to be replaced where there is evidence that they cannot be repaired. It also requires that applications for Listed Building Consent are supported by sufficient information to enable the local planning authority to determine them. This is why we ask for a survey to demonstrate that existing window(s) are beyond repair and need to be replaced. This is in addition to the elevational drawings and sections required. Please note that comprehensive window replacement is unlikely to be justified in all but exceptional circumstances.

### **What should be in a survey?**

The survey should be carried out by a joiner or similar and include each individual window. It should include an image of the whole elevation with the windows numbered and an accompanying proportionate amount of information about the type, age and condition of each window. For a straightforward residential property this could be an annotated photo with the windows numbered and a short description of the window condition. Additional information may be required for a more complex building or where significant historic windows are involved

## **Appendix 2: Building Standards Information**

### **Ventilation**

Every apartment must have a window(s) or door(s) with an opening area of at least 1/30th of the floor area of that room. Where the opening area of the existing window is already less than 1/30th of the floor, the opening area of the replacement window must not be less than the original size. If the existing window had an integral trickle ventilator the replacement window must also have an integral trickle ventilator of at least the same size as the original.

### **Safety from Collision**

Windows must not open over footpaths or any place to which the public has access, where they could form a hazard or obstruction.

### **Safety Glass**

Glazing which is less than 800 mm above the floor must be toughened or laminated. Alternatively, a protective barrier could be installed to prevent collision.

### **Thermal Insulation**

Windows must have a U-value (thermal insulation rating) of not more than 1.8 W/m<sup>2</sup>K. There are many types of window construction which meet the required degree of thermal insulation and this should be confirmed with the window installer.

### **Protective Barriers**

Openable windows to a storey with a floor level of at least 600 mm above the outside ground level, and with a cill height less than 800 mm above floor level, must be provided with a protective barrier to minimise the risk of falling from the window. On the ground and first storeys, the barrier must be not less than 800 mm above the floor level. There must not be any gaps in the barrier which would allow a 100 mm ball to pass through. Alternatively, permanently fixed safety glass may be used instead of a barrier.






## Emergency Escape Windows

An escape window must be provided in every apartment on the first floor of a dwelling. Escape windows must also be provided in rooms on the ground storey where the escape is through another room. Escape windows must have an unobstructed openable area that is at least 0.33 m<sup>2</sup> and at least 450 mm high and 450 mm wide. The bottom of the openable area must not be more than 1100 mm above the floor except in cases where the existing cill height is greater than 1100 mm.

## Safe Cleaning

All windows must be safely cleanable. Windows, all or part of which are more than 4 m above the adjacent ground level must be designed so that any external and internal glazed surfaces can be cleaned safely from inside the building. These windows must be cleanable whilst standing on the floor and without over-reaching. The maximum reach must not exceed that shown in the diagrams over, and the maximum upwards reach is 2150 mm. If parts of the existing window are out with the maximum reach, the replacement window should be of a type which allows those parts to be brought within the safe reach in order to allow safe cleaning.

All dimensions are in mm.



- (A) downwards reach through an opening light
- (B) side reach through an opening light
- (C) reach for cleaning an open window with easy-clean hinges