

MEMO



ABERDEEN
CITY COUNCIL

To	R Brown Planning & Infrastructure	Date	30/06/2017
		Your Ref.	170755
		Our Ref.	
From	Flooding		
Email	pa.flooding@aberdeencity.gov.uk		
Dial	01224 53 2387		
Fax			

Flooding
Communities, Housing and Infrastructure
Aberdeen City Council
Business Hub 11 ,
2nd Floor West,
Marischal College
Broad Street
Aberdeen AB10 1AB

Planning application no.170755

We would request that the applicant consider Rain water attenuation storage such as water butts are incorporated in the design. However this does not form a condition to be met prior to approval. In order to not increase the surface water run off, we would strongly recommend the adoption of permeable block paving. However this does not form a condition to be completed prior to approval.

Regards
Katy Joy Goodall - Flooding & Coastal

Bernadette Marjoram

Interim Corporate Director