

# MEMO



**ABERDEEN**  
CITY COUNCIL  
FLOODING  
**Communities, Housing and  
Infrastructure**  
Aberdeen City Council  
Business Hub 11 ,  
2<sup>nd</sup> Floor West,  
Marischal College  
Broad Street  
Aberdeen AB10 1AB

To	G Clark Planning & Infrastructure	Date	10/04/18
		Your Ref.	<b>180555</b>
		Our Ref.	
From	Flooding		
Email	<a href="mailto:pa.flooding@aberdeencity.gov.uk">pa.flooding@aberdeencity.gov.uk</a>		
Dial	01224 53 2387		
Fax			

## **Planning application no.180555**

ACC Flood Team have no objections to make on this application. However we would like to make the applicant aware that there is a risk of surface water flooding at the rear of the site. We would strongly recommend the use of permeable materials where suitable in the design and rainwater harvesting.

Regards  
Katy Joy Goodall - Flooding & Coastal

Bernadette Marjoram  
Interim Corporate Director