

# MEMO



ABERDEEN  
CITY COUNCIL

To	J Leadbeater Planning & Infrastructure	Date	26/06/18
		Your Ref.	<b>180974</b>
		Our Ref.	
From	Flooding		
Email	<a href="mailto:pa.flooding@aberdeencity.gov.uk">pa.flooding@aberdeencity.gov.uk</a>		
Dial	01224 53 2387		
Fax			

Flooding  
**Communities, Housing and Infrastructure**  
Aberdeen City Council  
Business Hub 11,  
2<sup>nd</sup> Floor West,  
Marischal College  
Broad Street  
Aberdeen AB10 1AB

## **Planning application no.180974**

ACC Flood Team would request that the applicant can confirm that the soakaway will have capacity for a M200 storm event. We note the proposed green roof and other innovations proposed in the design. We would recommend the use of rain water harvesting where suitable in the design.

Regards  
Katy Joy Goodall - Flooding & Coastal

Rob Polkinghorne

Chief Operating Officer

Operations and Protective Services